



- | | |
|---|---|
| <ul style="list-style-type: none"> ① Strengthening layer - Underlay bitumen membrane ② Transitional upstand of lightweight concrete ③ Bottom layer of waterproofing system on vertical surface - Underlay bitumen membrane ④ Top layer of waterproofing system on vertical surface - Cap sheet bitumen membrane ⑤ Vapour barrier to be fastened by self-tapping screws with washer \varnothing 50 mm at 500 mm intervals ⑥ Galvanized steel flashing ⑦ Roofing material flashing ⑧ Fasten by self-tapping screws at 200 mm intervals ⑨ Sealing mastic ⑩ Galvanized steel compensator to be mechanically fastened with flashing | <ul style="list-style-type: none"> ⑪ Material to be built-up on vertical surface and mechanically fastened by self-tapping screws with washer \varnothing 50 mm ⑫ CBPB or ACB ⑬ Galvanized steel profile not less than 3 mm in thickness ⑭ Stone wool thermal insulation ⑮ Vapour barrier for fixation of insulation ⑯ Galvanized steel compensator to be mechanically fastened with flashing ⑰ Galvanized steel profile to be fastened by rivets |
|---|---|

				EXPOSED FLAT ROOF	DESIGN	APPROVED
				EXPANSION JOINT AT JUNCTION TO WALL.	SCALE	DATE
REV.	DATE	DESCRIPTION	CHECKED	VARIANT 1	DWG No.	REV.