



- | | |
|--|--|
| ① Heat-treated needle-punched geotextile 150 g/sq.m | ⑪ Vapour barrier material for fixation of insulation |
| ② Washed gravel | ⑫ Vapour barrier material to be built-up on vertical surface and fastened by self-tapping screws with washer $\text{\O} 50 \text{ mm}$ |
| ③ Removable metal flashing | ⑬ Galvanized steel profile not less than 3 mm in thickness |
| ④ Galvanized steel compensator to be mechanically fastened with flashing | ⑭ CBPB or ACB |
| ⑤ Vapour barrier to be fastened by self-tapping screws with washer $\text{\O} 50 \text{ mm}$ at 500 mm intervals | ⑮ Stone wool thermal insulation |
| ⑥ Galvanized steel flashing | ⑯ Underlay bitumen membrane |
| ⑦ Roofing material flashing | ⑰ Cap sheet bitumen membrane |
| ⑧ Fasten by self-tapping screws at 200 mm intervals | ⑱ Galvanized steel profile |
| ⑨ Sealing mastic | |
| ⑩ Galvanized steel compensator to be fastened on wall by self-tapping screws | |

				TERRACE WITH DRAINAGE	DESIGN	APPROVED
					SCALE	DATE
REV.	DATE	DESCRIPTION	CHECKED	EXPANSION JOINT AT JUNCTION TO WALL	DWG No.	REV.