



,Notified Body No 1023
INSTITUTE FOR TESTING AND CERTIFICATION, Plc
Trida Tomase Bati 299, Louky, 763 02 Zlin, CZECH REPUBLIC

CERTIFICATE OF CONSTANCY OF PERFORMANCE No 1023-CPR-0718 P

Construction product: **Thermal insulation boards of mineral wool TECHNOFACADE COTTAGE / CERESIT CT 320 FACADE WOOL, TECHNOFACADE OPTIMA, TECHNOFACADE EXTRA**

Product parameters: **TECHNOFACADE COTTAGE / CERESIT CT 320 FACADE WOOL:** thicknesses: 50-200 mm, density:95-115 kg/m³, intended use: Thermal insulation for buildings
TECHNOFACADE OPTIMA: thicknesses: 50-200 mm, density:110-130 kg/m³, intended use: Thermal insulation for buildings
TECHNOFACADE EXTRA: thicknesses: 50-200 mm, density:80-100 kg/m³, intended use: Thermal insulation for buildings

Placed on the market under the name or trade mark of: **«Zavod Techno» LLC**
Ryazan, Vostochny promuzel 21,
b. 58, 390047 Russian Federation

Relevant standard(s): **EN 13162:2012+A1:2015** Thermal insulation products for buildings – Factory made mineral wool (MW) products – Specification

Final Report No: **753501211/2015, 753501537/2017, 753501843/2020**

Certificate first issued on: 2015-12-31

Notified Body No 1023, in compliance with Regulation (EU) No 305/2011 (CPR), attests that:

- All provisions relating to the Assessment and Verification of Constancy of Performance (AVCP) described in Annex ZA of the above harmonized standard(s) under **AVCP System 1** have been applied
- The performance of the construction product above has been assessed to remain constant.

The assessment of performance of the construction product and findings from the initial inspection of the manufacturing plant and factory production control are summarized in the above mentioned Final Report.

This certificate remains valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the Notified Body.



Jiří Heš

Representative of Notified Body No 1023

Revision b): 2020-09-29

Replaces the withdrawn certificate 1023-CPR-0718 P (Revision a) issued on 2017-11-30