



Notified Body No 1023
INSTITUTE FOR TESTING AND CERTIFICATION, Plc
Trida Tomase Bati 299, Louky, 763 02 Zlin, CZECH REPUBLIC

CERTIFICATE OF CONSTANCY OF PERFORMANCE No 1023-CPR-0775 P

Construction product: **Thermal insulation boards of mineral wool
TECHNOFLOOR STANDARD**

Product parameters: **TECHNOFLOOR STANDARD (thickness: 40-200 mm, density: 99-121
kg/m³): T4- DS(70,-) - DS(23,90)-CS(10)25-PL(5)50-WS-WL(P)-MU1-SD52-
AF_r 33, RtF:A1, λ_D= 0.037 W/(m.K)**

Intended use: **Thermal insulation for buildings**

Placed on the market
under the name
or trade mark of: **«Zavod Techno» LLC
Ryazan, Vostochny promuzel 21,
b. 58, 390000 Russian Federation**

Relevant standard(s): **EN 13162:2012+A1:2015 Thermal insulation products for buildings –
Factory made mineral wool (MW) products – Specification**

Final Report No: **753501346 / 2016**

Certificate first issued on: **2016-09-20**

Notified Body No 1023, in compliance with Regulation (EU) No 305/2011 (CPR), attests that:

- All provisions relating to the Assessment and Verification of Constancy of Performance (AVCP) described in Annex ZA of the above harmonized standard(s) under **AVCP System 1** have been applied
- The performance of the construction product above has been assessed to remain constant.


The assessment of performance of the construction product and findings from the initial inspection of the manufacturing plant and factory production control are summarized in the above mentioned Final Report.

This certificate remains valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the Notified Body.



Date of issue:

2016-09-20



Dr. Radomír ČEVELÍK
Representative of Notified Body No 1023