



- | | |
|--|---------------------------|
| ① Heat-treated needle-punched geotextile 150 g/sq.m | ⑤ Support |
| ② Washed gravel | ⑥ Compression metal clamp |
| ③ Top layer of waterproofing system at junction - Cap sheet bitumen membrane | ⑦ Metal rain collar |
| ④ Bottom layer of waterproofing system at junction - Underlay bitumen membrane | ⑧ Sealing mastic |
| | ⑨ Equipment support |

NOTES

Height of support above the roof surface should be not less than 800 mm to allow for possibility of roofing works and repairs.

				TERRACE WITH DRAINAGE	DESIGN	APPROVED
					SCALE	DATE
REV.	DATE	DESCRIPTION	CHECKED	SUPPORT FOR EQUIPMENT	DWG No.	REV.